
Fiber-top Micromachined Devices


technological output of Casimir force experiments


A question of money...













One little problem






From Mohideen and Roy, PRL 81 (1998) 4549




This is due to increased coupling of scattered light into the diodes from the approaching flat surface.


One little problem that shows up again






From Mohideen and Roy, PRL 81 (1998) 4549







Fiber-top technology


















SENSITIVE: based on optical interference

FLEXIBLE: working principle is not affected by the surroundings

COMPACT: just on the tip of a fiber

EASY-TO-USE: "plug-and-play" design

PORTABLE: readout in small volumes and light weight










Space missions



Quality inspection








Homeland security



Surgery rooms & medical applications

Environmental analysis







ATOMIC FORCE MICROSCOPY


Binnig, Quate, Gerber (1986)

one of the most spectacular application of microtechnology












BIOCHEMICAL SENSING

Cantilevers are widely used as biochemical detectors








Going back to Casimir...






CASIMIR FORCE MEASUREMENTS



Casimir force measurements with fiber-top technology



Considerations on the spring constant



$$k = \frac{1}{4} Ew \left(\frac{t}{L}\right)^3$$

Young Modulus:

$$SiO_2$$
: $E = 73$ GPa

Si:
$$E = 170 \text{ GPa}$$

$$Si_3N_4$$
: $E = 385$ GPa

$$w > 10 \mu m$$

However...
$$L < 100 \mu m$$


$$t > 4 \mu m$$

Can we decrease the spring constant?

Low k fiber-top devices




Torsional device






Torsional device: test





Low k fiber-top devices: test






Casimir force measurements with fiber-top devices


davide iannuzzi






Casimir force measurements with fiber-top devices






New device, no test: directly plugged into Casimir set-up



Casimir force measurements: challenges



 $d_{\scriptscriptstyle 0}$ Initial separation between the two surfaces



Casimir force measurements: challenges



 $d_{\scriptscriptstyle 0}$ Initial separation between the two surfaces

 \mathcal{E} Calibration constant (from V_{out} (in mV) to F_{out} (in pN))

 V_0


Casimir force measurements: challenges



 $d_{\scriptscriptstyle 0}$ Initial separation between the two surfaces


Calibration constant (from V_{out} (in mV) to F_{out} (in pN)) $V_0 \quad \text{Volta potential}$







 $F_{el} \propto [V_0 + V_{AC} \cdot \sin(\omega_1 t)]^2 = V_0^2 + 2V_0 V_{AC} \cdot \sin(\omega_1 t) + V_{AC}^2 \cdot \sin^2(\omega_1 t)$












V_0 : feedback on!


$$F_{el} = \frac{\epsilon_0 \pi R V_{AC}^2}{d} \cos(2\omega_1 t)$$


$$F_{el} = \frac{\epsilon_0 \pi R V_{AC}^2}{d} \cos(2\omega_1 t)$$
$$S_{out} = \xi \frac{\epsilon_0 \pi R V_{AC}^2}{d} \cos(2\omega_1 t)$$




davide iannuzzi Casimir force measurements: method READOUT $\downarrow d_0$ Feed-back loop drives $V_{ m DC}$ so that signal at ω_1 is zero known oscillation amplitude $2\omega_1$ frequency ω_1 ω_{res}
























de Man, Heeck, Wijngaarden, and DI Halving the Casimir force with conductive oxide Phys. Rev. Lett. **103** (2009) 040402








Halving the Casimir force with conductive oxides






Casimir force measurements: our "fortress"










Casimir force measurements: where are we?




Calibration curve (oscillation off)



Casimir force measurements: where are we?




Casimir curve (oscillation on): non-reproducible results



Casimir force measurements: where are we?



Casimir curve (oscillation on): a possible solution?



(also: much easier and less expensive fabrication process)

(IDEAS)µm = InterDisciplinary Engineering and Applied Sciences at the micron scale






Dhwajal Chavan (PhD student)



Kier Heeck (technical support)





Grzegorz Gruca (PhD student)



Jan Rector (technical support)



Sven de Man (PhD student)



Martin Slaman (technical support)



Audrius Petrušis (PhD student)



Nienke Alberts (Former member)



Kirsten Smith (Master student)







